



## TEST REPORT



No.of Cert.:L104  
TESTING

<b>Client</b>	Επαρχιακός Οργανισμός Αυτοδιοίκησης Λάρνακας	<b>Client's address</b>	
<b>Sample code</b>	Cy-2026-4032	<b>Sampling</b>	Veltia by client's order. Sampler Name : Antonis Poyiadjis-Sample Receiving Code: 12139
<b>Date of sample receipt</b>	10/03/2026	<b>Date of Import</b>	10/03/2026
<b>Sample description</b>	NEPO/WATER		
<b>Client's Declaration</b>	Νερό από σημείο στο δίκτυο Μενεού		
<b>Period of Analysis</b>	10/03/2026 - 13/03/2026	<b>Sample Condition</b>	Acceptable

Parameter	Method	Result	Unit	Accept. lev.
TVC@22°C	ISO 6222:1999	0	cfu/ml	No abnormal change (N.46(I)/23)
Total Coliform bacteria	ISO 9308-1:2014 & Amd1:2016	0	cfu/100ml	0 cfu/100ml
E. coli	ISO 9308-1:2014 & Amd1:2016	0	cfu/100ml	0 cfu/100ml
Intestinal enterococci	ISO 7899-2:2000	0	cfu/100ml	0 cfu/100ml
Pseudomonas aeruginosa	EN ISO 16266:2008	0	cfu/100ml	
Cl. perfringens	ISO 14189:2013	0	cfu/100ml	0 cfu/100ml

Notes

#Zero results indicate "Not Detected". The "0" in the results is for compliance purposes with regulatory limits.

\* Outside of the Scope of Accreditation. This Report may be reproduced in full as is. Partial reproduction and / or alterations are not allowed. The result of this certificate are valid only for the analyzed samples. The time of retention of the Sub-sample is 10 days from the date of the issuing of the present certificate, unless otherwise instructed by the client. This refers only to samples which can be kept during this period of time in appropriate conditions.

**Ζήνα Χριστοφή / Μικροβιολόγος, MSc**

**Ανθή Χατζηκωστή / Χημικός Μηχανικός**

*Zina Christofi / Microbiologist, MSc*

*Anthi Hadjicosti / Chemical Engineer*

**Technical Manager (Microbiology)**

**General Manager**

## ΑΞΙΟΛΟΓΗΣΗ ΑΠΟΤΕΛΕΣΜΑΤΩΝ

Αρ.Πιστ.	40-2592/18.03.2026/EN
Κωδικός Δείγματος	Cy-2026-4032
Περιγραφή Δείγματος	Νερό από σημείο στο δίκτυο Μενεού

Εντοπισμένο Πρόβλημα	Πιθανή Αιτία	Προτεινόμενη Διορθωτική Ενέργεια
The parameters that have been examined are within the limits outlined in the legislation concerning potable water/ Οι παράμετροι που έχουν εξεταστεί είναι εντός των ορίων που ορίζει η νομοθεσία για το πόσιμο νερό.		

**Ζήνα Χριστοφή / Μικροβιολόγος, MSc**

*Zina Christofi / Microbiologist, MSc*

**Technical Manager (Microbiology)**

**Ανθή Χατζηκωστή / Χημικός Μηχανικός**

*Anthi Hadjicosti / Chemical Engineer*

**General Manager**



No. of Cert.: L104  
**TESTING**

## TEST REPORT

<b>Client</b>	Επαρχιακός Οργανισμός Αυτοδιοίκησης Λάρνακας
<b>Client's address</b>	
<b>Sample description</b>	NEPO/WATER
<b>Sampling</b>	Veltia by client's order. Sampler Name : Antonis Poyiadjis-Sample Receiving Code: 12139
<b>Date of sample receipt</b>	10/03/2026
<b>Date of Import</b>	10/03/2026
<b>Sample code</b>	Cy-2026-4032
<b>Type of analysis</b>	Physicochemical

The results of this report are valid only for the analyzed samples.  
This Report may be reproduced in full as is.  
Partial reproduction and / or alterations are not allowed.  
For any information please contact the commercial department.

## Results

**Sample Code**                    **Cy-2026-4032**  
**Period of Analysis**           **11/03/2026 - 18/03/2026**  
**Client's Declaration**        **Νερό από σημείο στο δίκτυο Μενεού**  
**Sample condition upon receipt**                    **Acceptable**

Parameter	Units	Result	Reporting limit	Uncertainty at the accept. level	Max. accept. lev.**	Method
pH	μονάδες pH	<b>8,2</b>	2,0 - 12,0		<b>6,5 - 9,5</b>	ISO 10523:2008
Electrical Conductivity	μS/cm in 20oC	<b>664</b>	-	1,5%	<b>2500</b>	ISO 7888:1985
Color	Units Pt-Co	<b>N.D.</b>	10		-	In house method based on HACH Application DOC 316.53.01252*
Odor	-	<b>Acceptable</b>	-		-	In house method*
Turbidity	NTU	<b>0,67</b>	0,50		<b>1,0</b>	In-house method based on APHA 2130B

St. Met.: APHA, Standard Methods 24th Ed, 2023.

N.D.: Not determined at the reporting limit of the method.

\* **Outside of the Scope of Accreditation.**

\*\***Max. acceptable levels** described and explained as to their proper use in Cyprus Regulation 46(I)/2023 and its amendments.

The above legislative limits are valid until the day the test report is issued.

# The time of retention of the Sub-sample is one month from the date of the issuing of the present certificate, unless otherwise instructed by the client. This refers only to samples which can be kept during this period of time in appropriate conditions.

**Κλεοπάτρα Χαραλάμπους/Χημικός, MSc**

*Cleopatra Charalambous/Chemist, MSc*



**Technical Manager (Chemistry)**

**Ανθή Χατζηκωστή / Χημικός Μηχανικός**

*Anthi Hadjicosti / Chemical Engineer*



**General Manager**